intertek
Total Quality. Assured.

Intertek B&C
1909 10th St. Suite 100
Plano, TX 75074

Tel +1 469 814 0687
intertek.com

October 2, 2026

David Bradbury
Hi Tech Roof Solutions
1351 E. FM 487
Jarrell, Texas 76537

RE: Test Results for Job no. U3394.01-801-44

Dear David Bradbury,

UL 2218 testing was recently performed on 10/02/26 by Intertek[1] Building & Construction (B&C) on Hi Tech Roof Solutions ArmourShield Ultra Protector at the Intertek test facility in Plano,TX. Sample tested had an overall size of 36" x 36".

The test specimen was tested in accordance with UL2218. The test specimen successfully met all of the performance requirements in the above referenced standard for a Class 4 rating.

A comprehensive test report including test specimen description and test data will be forthcoming. If you have any questions, please feel free to contact me at your convenience. This document is a letter of results; it is not a test report.

Sincerely,
INTERTEK B&C

Jeffrey Crump
Laboratory Manager
cc: U3394.01-801-44-LOR

[1] Intertek is a brand name representing the Intertek Group plc legal entities, including but not limited to, Intertek Testing Services NA Inc., Professional Service Industries, Inc. ("INTERTEK-PSI"), **Architectural Testing Inc. ("INTERTEK-ATI")**, and MT Group Inc. ("INTERTEK-MT").

This Letter of Results (LOR) is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this LOR. Only the Client is authorized to permit copying or distribution of this LOR and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this LOR are relevant only to the sample(s) tested. This LOR by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.